

PITTSFORD WATER DEPT – VT0005225

Consumer Confidence Report – 2009

This report is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. This report is designed to inform you about the quality water and services we deliver to you every day. To learn more, please attend any of the Water & Sewer Commission regularly scheduled meetings which are held the third Tuesday of each month at 6:30 PM at the Pittsford Town Office, 426 Plains Road, Pittsford, VT. Meeting agendas are posted at the Pittsford Town Office, Pittsford Post Office, Florence Post Office and on the Town of Pittsford website www.town.pittsford.vt.us. For more information please contact JOHN HAVERSTOCK, Town Manager at 802-483-6500, ext. 20. Operator: Bruce Babcock, Water & Sewer Superintendent (802) 483-6500, ext. 19.

Water Source Information

Your water comes from

Source Name	Source Water Type
SAND SPRING	Ground Water
THE WALKER SPRINGS 1	Ground Water
THE WALKER SPRINGS 2	Ground Water
THE WALKER SPRINGS 3	Ground Water
THE WALKER SPRINGS 4	Ground Water
THE WALKER SPRINGS 5	Ground Water

The State of Vermont Water Supply Rule requires Public Community Water Systems to develop a Source Protection Plan. This plan delineates a source protection area for our system and identifies potential and actual sources of contamination. Please contact us if you are interested in reviewing the plan.

Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). As water travels over the land's surface or through the ground, it dissolves naturally-occurring minerals. It also picks up substances resulting from the presence of animals and human activity. Some "contaminants" may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants, if any are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the past year. It also includes the date and results of any contaminants that we detected within the past five years if tested less than once a year. The presence of these contaminants in the water does not necessarily show that the water poses a health risk.

Terms and abbreviations - In this table you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Maximum Contamination Level Goal (MCLG): The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

Maximum Contamination Level (MCL): The “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectants in controlling microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. Addition a disinfectant may help control microbial contaminants.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

90th Percentile: Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level).

Treatment Technique(TT): A process aimed to reduce the level of a contaminant in drinking water.

Parts per million (ppm) or Milligrams per liter (mg/l): (one penny in ten thousand dollars)

Parts per billion (ppb) or Micrograms per liter (µg/l): (one penny in ten million dollars)

Picocuries per liter(pCi/L): a measure of radioactivity in water

Nephelometric Turbidity Unit (NTU): NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Running Annual Average (RAA): The average of 4 consecutive quarters (when on quarterly monitoring); values in table represent the highest RAA for the year

Detected Contaminants PITTSFORD WATER DEPT

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2008				

Chemical Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
NITRATE	3/13/2007	0.9	0.9	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

NITRATE-NITRITE	2/26/2008	0.9	0.9	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
ZINC	3/13/2007	0.13	0.13	MG/L	5		

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2008							

Disinfection ByProducts	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2008							

Lead and Copper	Date	90 th Percentile	95 th Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2005 - 2007	0.12	0.18	0.03 - 0.23	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2005 - 2007	3	4	1 - 4	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Violation(s) that occurred during the year

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. The below table lists any drinking water violations we incurred during 2008. A failure to perform required monitoring means we cannot be sure of the quality of our water during that time.

Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2008			

Health information regarding drinking water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

There are no additional required health effect notices.

Temporary Operating Permit Public Notice

The **Pittsford Water Department (the Water System)**, a public water system under the laws of the State of Vermont, was recently reissued a Temporary Operating Permit. The Secretary of the Agency of Natural Resources found that such issuance will not unreasonably contribute to a public health risk, although the **Pittsford Water Department** does not presently comply with certain requirements of the Federal Safe Drinking Water Act and applicable state statutes and rules. The nature and extent of the noncompliance are as follows:

The Water System does not provide adequate water distribution system pressure or fire flow volume to meet the requirements of the Vermont Water Supply Rule. The Water System is following a financial long range plan and improvement schedule to correct water system deficiencies as quickly and cost effectively as possible in coordination with the State of Vermont Agency of Transportation Route 7 corridor improvements project. The Water System is following through on specific recommendations made by the Water Supply Division to eliminate potential sanitary hazards and provide for future system durability and reliability. In accordance with the Vermont Water Supply Rule, the Division has requested the timely resolution of all water system deficiencies. To obtain more specific information regarding these necessary public drinking water improvements, please call John Haverstock, Town Manager at (802) 483-6500 ext. 20. Operator: Bruce Babcock, Water & Sewer Superintendent (802) 483-6500 ext. 19.

Town of Pittsford
Municipal Office
P. O. Box 10, 426 Plains Road
Pittsford, VT 05763

Bulk Rate #1
US Postage
PAID
Pittsford, VT 05763

RETURN SERVICE REQUESTED